

February 6, 2013

Alan Anderson
NPDES Enforcement Section
Arkansas Department of Environmental Quality
5301 North Shore Dr
North Little Rock, Arkansas 72118

RE: Storm water Blending January 29, 2013 thru January 30, 2013
Russellville City Corporation Pollution Control Works
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Tuesday January 29, 2013 and ending Wednesday January 30, 2013. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 2,057,000 gallons estimated.

Tuesday, January 29, 2013

Total Suspended Solids	14.5 mg/l	CL2	0.03 mg/l
Dissolved Oxygen	7.4 mg/l	pH	6.56
Ammonia	7.93 mg/l	BOD	5.1 mg/l
Fecals	40/100ml		

Wednesday, January 30, 2013

Total Suspended Solids	11.9 mg/l	CL2	0.09 mg/l
Dissolved Oxygen	7.7 mg/l	pH	6.31
Ammonia	6.00 mg/l	BOD	4.9 mg/l
Fecals	70/100ml		

Sincerely,

Steve Mallett
General Manager

cc: Ricky Biffle
Randy Bradley
File