

March 19, 2013

Alan Anderson
NPDES Enforcement Section
Arkansas Department of Environmental Quality
5301 North Shore Dr
North Little Rock, Arkansas 72118

RE: Storm water Blending March 10, 2013 thru March 14, 2013
Russellville City Corporation Pollution Control Works
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Sunday March 10, 2013 and ending Thursday March 14, 2013. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 16,456,000 gallons estimated.

Monday, March 11, 2013

Total Suspended Solids	34.5 mg/l	CL2	0.01 mg/l
Dissolved Oxygen	8.6 mg/l	pH	6.27
Ammonia	3.16 mg/l	BOD	36.3 mg/l
Fecals	77/100ml		

Tuesday, March 12, 2013

Total Suspended Solids	53.0 mg/l	CL2	0.01 mg/l
Dissolved Oxygen	7.3 mg/l	pH	6.27
Ammonia	0.90 mg/l	BOD	14.4 mg/l
Fecals	800/100ml		

Wednesday, March 13, 2013

Total Suspended Solids	63.7 mg/l	CL2	0.03 mg/l
Dissolved Oxygen	7.4 mg/l	pH	6.34
Ammonia	2.15 mg/l	BOD	28.4 mg/l
Fecals	148/100ml		

Thursday, March 14, 2013

Total Suspended Solids	46.7 mg/l	CL2	0.01 mg/l
Dissolved Oxygen	7.8 mg/l	pH	6.50
Ammonia	1.92 mg/l	BOD	21.1 mg/l
Fecals	220/100ml		

Sincerely,

Steve Mallett
General Manager

cc: Ricky Biffle
Randy Bradley
File