

January 22, 2014

Alan Anderson
NPDES Enforcement Section
Arkansas Department of Environmental Quality
5301 North Shore Dr
North Little Rock, Arkansas 72118

RE: Storm water Blending January 10, 2014 thru January 11, 2014
Russellville City Corporation Pollution Control Works
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Friday January 10, 2014 and ending Saturday January 11, 2014. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 2,244,000 gallons estimated.

Friday, January 10, 2014

Total Suspended Solids	49.0 mg/l	CL2	0.01 mg/l
Dissolved Oxygen	8.9 mg/l	pH	6.63
Ammonia	7.04 mg/l	BOD	27.1 mg/l
Fecals	11,200/100ml		

Sincerely,

Steve Mallett
General Manager

cc: Ricky Biffle
Randy Bradley
File